

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3225-0751:101

Page 1 of 1

**CATEGORY:** Fire Dampers

**LISTEE:** Safe-Air, 1855 S. 54th, Cicero IL 60804  
Contact: \*Lee Stack (708) 652-9100

**DESIGN:** Models 420 and 420R ceiling dampers. Model 420 is square or rectangular and Model 420R is round. Refer to listee's data sheet for additional detailed product description and operational considerations.

Model	Min. Width	Min. Length	Max. Width	Max. Length
420	4"	4"	24"	24"
420R	4" Diameter		24" Diameter	

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, classification and UL label.

**APPROVAL** Listed as ceiling dampers for installation inside duct outlets in rated fire resistive floor or roof ceiling assembly with a restrained and/or unrestrained assembly up to 3-hour.

\*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager